

2025 Annual Drinking Water Quality Report

CITY OF SCHULENBURG

Public Water System ID: TX0750004

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono 979-743-4126.

For more information regarding this report, contact:

Name: Tami Walker

Phone: 979-743-4126

Sources of Drinking Water

CITY OF SCHULENBURG is Ground water.

Our water source(s) and source water assessment information are listed below:

Source Name		Type of Water	Report Status	Location
1 - PLUGGED		Ground water	NO	605 UPTON
10 - PS1 / UPTON AVE	PS1 / UPTON AVE	Ground water	YES	605 UPTON
11 - PS2 / LLOYD LN	PS2 / LLOYD LN	Ground water	YES	605 UPTON
12 - PS1 / WOLTER'S PARK	PS1 / WOLTER'S PARK	Ground water	YES	605 UPTON
13 - LYONS AVE		Ground water	YES	605 UPTON
2 - PLUGGED		Ground water	NO	605 UPTON
3 - PLUGGED		Ground water	NO	605 UPTON
5 - CITY PARK / PLUGGED	CITY PARK	Ground water	NO	605 UPTON
6 - PS1 / PUMP HOUSE	PS1 / PUMP HOUSE	Ground water	YES	605 UPTON
7 - KALLUS / WOLTER (PLUGGED)	KALLUS / WOLTER	Ground water	NO	605 UPTON
8 - PS2 / HENDERSON HILL	PS2 / HENDERSON HILL	Ground water	YES	605 UPTON
9 - PS3	PS3	Ground water	YES	605 UPTON

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally—occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottle water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800)426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban storm water runoff and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color or odor problems. These type of problems are not necessarily causes for health concerns. For more information on taste, odor or color of drinking water, please contact the system's business office.

Some people may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancers; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).

The City of Schulenburg Public Water System has completed a lead service line inventory in 2024. Results can be found at City Hall located at 605 Upton.

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. The City of Schulenburg is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact City of Schulenburg at 979-743-4126. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

In the tables below, you will find terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Action Level (AL)	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG)	The level of contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Level 1 Assessment	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment	A Level 2 assessment is very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.
Maximum residual disinfectant level goal or MRDLG	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Treatment Technique or TT	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions	State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
<u>Avg: Average</u>	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
<u>RAA</u>	Running Annual Average
<u>LRAA</u>	Location Running Annual Average
<u>mrem</u>	millirems per year (a measure of radiation absorbed by the body)
<u>na</u>	not applicable
<u>ppb</u>	micrograms per liter (ug/L) or parts per billion—or one ounce in 7,350,000 gallons of water
<u>ppm</u>	milligrams per liter (mg/L) or parts per million - or one ounce in 7,350 gallons of water.
<u>Picocuries per liter (pCi/L)</u>	Picocuries per liter is a measure of the radioactivity in water.

Disinfectant Residual

All public water systems in Texas are required to disinfect drinking water to ensure control of microbial contaminants. Disinfectants are water additives used to control microbes.

Disinfectant	Year	Average Level	Unit	Range	MRDL/MRDLG Goal
Chlorine Free	2025	2.56	Mg/L	1.00-4.00	4/4

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2023 - 2025	0.129	0.0116 - 0.132	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2023 - 2025	0	0 - 1.19	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	202 RUSSEK BLDG D	2025	3	2.6	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	FIRE STA: 814 WOLTERS, SCHULENBURG	2025	6	5.8	ppb	60	0	By-product of drinking water disinfection
TTHM	202 RUSSEK BLDG D	2025	13	12.8	ppb	80	0	By-product of drinking water chlorination
TTHM	FIRE STA: 814 WOLTERS, SCHULENBURG	2025	71	71.4	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	10/27/2025	0.0896	0.0801 - 0.0896	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
DIBROMOCHLOROMETHANE	9/22/2025	21.3	1.9 - 21.3	UG/L	0	0.06	
FLUORIDE	4/3/2023	0.43	0.37 - 0.43	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
THALLIUM, TOTAL	10/27/2025	0.43	0 - 0.43	ppb	2	0.5	Leaching from ore-processing sites; Discharge from electronics, glass, and drug factories

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	6/10/2021	1.5	1.5	pCi/L	5	0	Erosion of natural deposits
GROSS BETA PARTICLE ACTIVITY	6/10/2021	12.1	7.5 - 12.1	pCi/L	50	0	Decay of natural and man-made deposits.

Violations

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
12/30/2025 - 1/8/2026	LEAD & COPPER RULE	LEAD CONSUMER NOTICE (LCR)	Failed to meet content, delivery, and/or reporting requirements for lead consumer notification

There are no additional required health effects notices.

There are no additional required health effects violation notices.